

Certificate of Analysis

Honeywell reference	:	83334469 / 1462315
Customer Order ref	:	366
Product name	:	AZ-20 R410a : mixture of pentafluoroethane 50 % and difluoromethane 50 %
quantity	:	approx. 17.327 kgs in 1 isotank
Container number	:	EURU 532612-9
Analysis of:	Unit:	Analysis:
R32	%w	50.00
R125	%w	50.00
Purity	%w	99.98
Water content	Ppm w/w	4.5
Air in vapor phase container	% Vol	0.61
Chloride ion test		negative
High boiling residue	% vol	ND

This certificate is issued in compliance with standard operating procedures of Honeywell Fluorine Products approved by
T.G.A. Vink Director Regulatory Affairs & QA